



कार्यालय नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर

पत्रांक : 1343 | ट्रॉफी | ८०८ | ८०८

दिनांक : 16/12/2022

प्रमाण पत्र

प्रमाणित किया जाता है कि सफाई एवं खाद्य निरीक्षक/केमिस्ट स्वास्थ्य विभाग द्वारा दिनांक 12.12.2022 को गार्डनिया पब्लिक स्कूल, 91/1 राधापुरम गोवा गार्डन कल्यानपुर कानपुर नगर का निरीक्षण किया गया तथा पानी का सैम्पल लिया गया जिसमें पेयजल की गुणवत्ता एवं सेनेटरी एवं हाइजेनिक स्थितियां हैत्य मैनुअल के अनुरूप सही पायी गयी हैं।

नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर
नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर





KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the	<u>Mrs GARDENIA PUBLIC SCHOOL</u>	, 911 RADHAP
Sample taken from -	<u>SUB MERCIBLE</u>	<u>GOOBA GARDEN</u>
Date of sample Drawn -	<u>12/12/2021</u>	<u>KALYANPUR</u>
Date of analysis -	<u>12/12/2021</u>	-
Physical Character -	<u>TRANSPARENT</u>	-
P. H. Value -	<u>7.96</u>	-
Free Ammonia Parts per 1000000 -	<u>NIL</u>	-
Albuminoid Ammonia Part per 1000000 -	<u>NIL</u>	-
Oxygen absorbed from pot. Permagnate in three hours at 37°C -	<u>0.4</u>	-
Chloride Part per 1000000 -	<u>95.00</u>	-
Nitrates Parts per 1000000 -	<u>TRACE</u>	-
Nitrites Parts per 1000000 -	<u>TRACE</u>	-
Total solid part per 100000 -	<u>930.00</u>	-
Fixed solid Parts per 1000000 -	<u>840.0</u>	-
Volatile solid Parts per 100000 -	<u>150.0</u>	-
Appearance on ignition -	<u>No CHARRING</u>	-
Total hardness Parts per 1000000 -	<u>540.00</u>	-
Permanent hardness Parts per 1000000 -	<u>460.00</u>	-
Temporary hardness Parts per 1000000 -	<u>80.00</u>	-

Remarks :

'POTABLE'



No 293/C/2021 Dated 16/12/2021

Copy forwarded for favour or information to

Mrs Gardenia Public School
911 Radhepram, Gooba Garden
Kalyanpur, Kalyanpur Nagar

ALKASINGH
(Chemist)

Nagar Swasthya Adhikari

Nagar Nigam Kalyanpur

नगर स्वस्थ अधिकारी

नगर निगम काल्यापुर

21 A.S.A. Kalyanpur Nagar, Nagar Nigam Kalyanpur

K.N.N. PRESS

293/ewA/Bhar 16/12/2021



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from GARDENIA PUBLIC SCHOOL, 91/1, RADHA PURA, GROSH GARDEN, KALYANPUR, KANPUR NAGAR.
Name & designation of the person collecting samples: ALKA SINGH - CHEMIST (JAI)

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count				Probable no. of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS
		at 37°C in 48 hours	at room temperature in 72 hours	Quantity of water put in each tube No. of tubes put up	5ML	10 ML	1 ML			
16/12/2021	GARDENIA PUBLIC SCHOOL	19	64	—	NIL	1	1	ZERO	NIL	SATISFACTOR

Remarks:- Chlorination is necessary for Disinfection / P.R.C. must be 0.2 ppm.

Copy for Information Forwarded to (1) Mr. Gardenia Public School

(2) A.S.A. Kanpur Nagar Nigam

ALKA SINGH, Nagar Sangathan Adhikari
(Chemist) नगर सिंग चम्पुर
Nagar Nigam Kanpur

